

Emission Test Certificate

Tuesday 11th March 2019

Supplier: Dunlop Flooring (86 Berkshire Road, North Sunshine, Victoria, 3020, Australia)

Sample Description: Frontier Elementary Dryback 2 mm

Date Tested: February 2019 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: ASTM D5116-2017 “Standard Guide for Small-Scale Environmental Chamber Determinations of Organic Emissions from Indoor Material/Products”.

Emission Data (24 hours):


<p>Green Building Council of Australia Green Star Design & As Built v1.1 - 13.1.2B & 13.2 Green Star Interiors V1.1 - 12.1.2B</p>	<p>Frontier Elementary Dryback 2 mm</p>
<p>Total Volatile Organic Compound Emission Rate Limit: <0.500 mg/m²/hr</p>	<p>Total Volatile Organic Compound Emission Rate: 0.204 mg/m²/hr</p>
<p>4-phenylcyclohexene Emission Rate Limit: <0.05 mg/m²/hr</p>	<p>4-phenylcyclohexene Emission Rate: <0.005 mg/m²/hr</p>
<p>Formaldehyde Emission Rate Limit: <0.1 mg/m²/hr</p>	<p>Formaldehyde Emission Rate: <0.006 mg/m²/hr</p>



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant



Nick Joy
BSc(Hons)
Consultant



Tuan Duong
B.Eng. (Chemical)
Consultant

CV190231